

小型浄化槽新旧一覧（単独）

2023/12/15作成

機種名	処理方式	人槽	発売時期 (和暦)	発売時期 (西暦)	終了時期 (和暦)	終了時期 (西暦)	マンホール枚数（樹脂製）				汚泥引き抜き (m³)	必要風量 (L/分)	
							Φ 250	Φ 450		Φ 500			
								478mm	492mm	502mm	560mm		
NS	変型二階腐敗タンク・平面酸化	5	S45.10	1970.10	S56.4	1981.4	3	1				1.550	
		7					3					1.700	
		10					3	1				2.060	
AS	全ばっ気	5	S46.9	1971.9	確認中	確認中		1				0.780	40
		8						1				0.933	40
		10						1				1.028	40
AB	全ばっ気	5	S49.10	1974.10	S56.4	1981.4		1				0.759	40
		8						1				0.923	40
		10						1				1.032	40
FS	分離ばっ気	5	S49.11	1974.11	S56.4	1981.4		2				1.066	40
		7						2				1.329	40
		10						2				1.617	60
AS II	全ばっ気	5	S50.7	1975.7	S56.4	1981.4		1				0.762	40
		8						1				0.894	40
		10						1				0.992	40
NB	腐敗タンク	5	S50.8	1975.8	S56.4	1981.4		2				1.510	
		7						2				1.710	
		10						2				2.010	
FS II	分離ばっ気	5	S53.1	1978.1	S56.4	1981.4		2				1.086	30
		7						2				1.288	30
		10						2				1.578	30
AB II	全ばっ気	5	S53.4	1978.4	確認中	確認中		1				0.760	
		8						2				0.758	40
		10						2				1.025	40
E	分離接触ばっ気	5	S56.5	1981.5	S57.5	1982.5		2				1.203	40
		8						2				1.378	30~40
		10						2				1.538	30~40
S	分離ばっ気	5	S56.5	1981.5	H3.11	1991.11		1				1.754	30~40
		6						1				1.934	40
		7						1				2.275	40
E II	分離接触ばっ気	5	S57.1	1982.1	S63.12	1988.12		2				0.753	30~40
		6						2				0.840	30~40
		7						2				0.943	30~40
ST	分離ばっ気	8	S57.2	1982.2	S63.12	1988.12		2				1.024	30~40
		10						2				1.200	30~40
		5	S57.2	1982.2	H1.2	1989.2		2				1.352	30~40
ST	分離ばっ気	6						2				1.550	30~40
		7						2				1.733	30~40
		8						2				1.917	40
S I	分離ばっ気	10	S61.12	1986.12	H3.7	1991.7		2				2.199	40
SP	分離ばっ気	5	S60.9	1985.9	S62.12	1987.12		2				1.227	30~40
		6	S60.10	1985.10	S63.4	1988.4		2				1.372	30~40
		7						2				1.502	30~40
EP	分離接触ばっ気	5	S63.1	1988.1	H11	1999		2				0.752	30
		6						2				0.850	30
		7						2				0.934	30
EC	分離接触ばっ気	10	H3.2	1991.2	H11	1999		2				1.208	40

※マンホール枚数は本体のみになります。